

# VERIFICATION

## EMF

Order No. **1122567/M**

Type of appliance **Heater for mounting in ventilation duct**

Applicant **VEAB Heat Tech AB**

Address **Box 265, SE-281 23 Hässleholm, Sweden**

Brand name **VEAB**

Type designation **VFLPG\*\*\*x\*\*\*-\*\*\*, VTL\*\*\*x\*\*\*-\*\*\*,  
VFL\*\*\*x\*\*\*-\*\*\*, VRA\*\*\*x\*\*\*-\*\*\***

### TEST INFORMATION

Type of testing **Measurement of electromagnetic field according to standard  
EN 62233:2008**

Summary **The appliance has shown compliance with the requirements in  
standard EN 62233:2008  
This verification is based on the test report no 1122567/M1**

**Kista-Stockholm** 20 January 2012

**Intertek Semko AB**  
Household Appliances and HVAC



*Christoffer Johansson*

---

*Intertek Semko AB's laboratories in Kista, Sweden complies with the requirements of EN ISO/IEC 17025.*