

Test Verification of Conformity

Verification Number: 2027433STO-103

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it.

Once compliance with all product relevant **CE** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

| | |
|---|---|
| Applicant Name & Address: | VEAB Heat Tech AB Stattenavägen 50 281 23 Hässleholm, Sweden |
| Manufacturer Name & Address: | VEAB Heat Tech AB Stattenavägen 50 281 23 Hässleholm, Sweden |
| Product Description: | Duct heater |
| Ratings & Principle Characteristics: | 400 V3~ 50/60 Hz 15000 W IP 43, class: I, 400 V3~ 50/60 Hz 12000 W IP43, class I, 400 V3~ 50/60 Hz 9000 W IP 43, class: I, 400 V3~ 50/60 Hz 6000 W IP 43, class I and 400 V3~ 50/60 Hz 5000 W IP 43, class: I |
| Models/Type References: | CV *_*_***** |
| Brand Name(s): | VEAB |
| Standard(s)/Directive(s): | EN IEC 61000-6-1:2019 and EN 61000-6-3:2007+A1:2011 / 2014/30/EU |
| Verification Issuing Office Name & Address: | Intertek Semko AB Torshamnsgatan 43, Box 1103, SE-164 22 Kista, Sweden |
| Test Report Number(s): | 2027433STO-102 |

Signature



Name: Love Eriksson

Position: Technical leader, EMC

Date: February 8, 2020

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.